



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/06/2026

Area: CHP

Equipment	Job
CC-7,8 GALLERY	12NO'S 75W LED installed and 20m cable laid and 5no's lights circuit rectified and kept in line
CC-17,18 T/E	200W LIGHT arranged
JH-3,5	Hoists PPM done
CC-15,19	Panel and motor side PPM done
CC-115	Gallery lighting improved
CC-51,51A	Panel and motor side PPM done
CC-111,112,31,32,33	Machines PCRD checking done
CC-47,48 GALLERY	Lighting rectification and improvement done
CC-45,CC-111,RECL-1	Running inspection done
CC-46,CC-104,SCR-6	PPM work done