



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/06/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Tbs on co 24	no power ,wrong complaint,emergency PB acted	power ok,E PB released	08:20:00	08:30:00	
2	OHP	TBS on CO 5A	LT not working,OT acted	OT released	10:45:00	10:55:00	
3	CHP	CC 38 SCr5	LT not working,m5 mpcb tripped,track jamming heavily	made it on,informed operation for jamming	10:00:00	10:15:00	
4	CHP	CC 201 and 203	mpd acted	reset	10:30:00	10:40:00	
5	CHP	CC 32 SCR4	LT not working,OT acted	OT released	12:10:00	12:20:00	
6	WT	Co 3(B)	ZSS problem,probe damaged	probe replaced	08:30:00	08:40:00	