



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 28	B/C OLR ACTED	RESET	19:00:00 20:50:00	19:15:00 21:05:00	
2	OHP	BRC ON CO 33M B/W 2	INTERLOCK PANEL ALL TBS TIGHTENED	THEN OK	20:45:00	21:30:00	
3	CHP	CC 45	CONTROL MCB PROBLEM	REPLACED	20:15:00	20:40:00	
4	CHP	CC 125	OLR ACTED	RESET	20:20:00	20:25:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	17:50:00	21:40:00	8 TIMES
6	CHP	CC 113A F/G	OLR ACTED	RESET	14:35:00	14:45:00	
7	WT	OT 3	TRIPPING FREQUENTLY MECH PROBLEM	RESET AND INFORMED TO MECH	19:00:00	19:30:00	