RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 13/10/2026

Area: CHP

Equipment	Job
CC 113	R/L selector switch replaced
CC 58 D2	Motor termination done and trail run taken,alignment to be done
JH 18	Cable tray cleaning done
CC 40,SCR 7	PPM was done
LC 17(CM-21),CM 15	Bus bar maintenance was done