



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/09/2026

Area: CHP

Equipment	Job
CC 202	Lighting ckt problem rectified
CC 202	BRS kept in ckt
LC 17,18	Transformer rooms cleaning done
CC 222/223	Slope area lighting ckt problem rectified,10 nos 30W LED lamps provided
CM 17,18,LC 18	IO rack maintenance done
160 KW Spare	Motor fan fabricated and fixed.Trail run taken ,found ok
CC 39 to CC 213	Space heaters inspection done
CC 215,216	Belt scale maintenance was done
JH 209,210,211,212	Hoist panels maintenance done
CC 48,49	PPM was done
CC 130,131	PPM was done