



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/05/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 76R	TRIPPED ON OLR /3TIMES	RESET DONE	06:50:00	07:00:00	
2	OHP	CO3A	BRS ACTED	RESET DONE	08:45:00	09:00:00	
3	OHP	RCO 2A	BSS ACTED HANDLE STUCKUP	RESET DONE	12:50:00	13:00:00	
4	CHP	CC 28	TRIPPED ON OLR /2 TIMES	RESET DONE	10:45:00	11:00:00	
5	CHP	SCR 1 ON CC31	SLEW NOT TAKING PLACE/DRIVE TRIPPED	RESET DONE	12:25:00	12:40:00	
6	CHP	SCR 4 ON CC32	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED	TENSION RELEASED	10:20:00	10:30:00	
7	CHP	CC 125	TRIPPED ON OLR	RESET DONE	13:10:00	13:20:00	
8	CHP	CC 28	TRIPPED ON OLR	RESET DONE	13:15:00	13:25:00	
9	CHP	CC 109	BRS ACTED/NO POWER TO MODULE	BYPPED AT I/O RACK	12:15:00	12:30:00	IN FORM TO G SHIFT TO KEEP IN CKT
10	WT	OP 5	F/R NOT TAKING PLACE	D5 TRIPPED ON OLR/RESET DONE	09:40:00	09:55:00	