



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 1	power mpcb tripped	made it on	09:20:00	09:25:00	3 times with half an hour gap
2	OHP	VS 2	OLR acted	reset	09:40:00	09:45:00	
3	OHP	CO 10 A	olr acted	reset	11:30:00	11:35:00	
4	OHP	TBS on CO 19	LT not working,drive tripped in ol,thruster brake base bolt missing	drive reset ,thruster brake loose	06:40:00	07:00:00	
5	OHP	BRC on CO 8A	LT not working,olr acted	reset	07:10:00	07:25:00	
6	OHP	TBS on CO 7A	LT not working,OT acted	Ot released	07:55:00	08:10:00	
7	OHP	CO 84	ZSS acted return wire connected wrong in module	kept in correct tb	07:55:00	08:10:00	
8	OHP	WOBR on CO 29	LT not working,drive tripped	reset	11:30:00	11:40:00	
9	CHP	CC 58	tripped in curt sp	reset	06:10:00	06:20:00	
10	CHP	CC 52	MPD acted	reset	09:30:00	09:35:00	2 times