



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 33m	OLR acted	Reset	19:00:00	19:05:00	
2	OHP	CO 29	OLR acted	Reset	19:35:00	21:30:00	2 times
3	OHP	BRc on Co 8a It	Incomer in Off condition	Made it on	21:25:00	21:40:00	