



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 04/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	03:40:00 23:25:00	03:45:00 23:35:00	
2	OHP	BRC ON CO 34 CT	EMERGENCY STOP ACTED IN DRIVE PANEL	RELEASED	00:20:00	00:30:00	
3	OHP	BRC ON CO 28 CT	GUIDE ROLLER PROBLEM	INFORMED TO MECH	01:20:00	01:40:00	
4	OHP	WBR ON CO 6A	SLEW LEFT IS MOVING SLOW	SOLENOID VALVES TIGHTENED THEN OK	23:50:00	00:10:00	
5	CHP	SCR 2 ON CC 33 B/C	30 DEGREE LIMIT ACTED	SLEW DONE THEN OK	22:30:00	22:40:00	
6	CHP	CC 45 ZSS ACTED	CAGE PROBLEM	REPLACED	01:25:00	01:45:00	
7	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	01:30:00	01:35:00	
8	CHP	CC 29	OLR ACTED	RESET	05:30:00	05:40:00	
9	WT	OP1	BREAKER TRIPPED IN LC 2A	MADE IT ON	03:30:00	03:40:00	
10	IOSA	OM 7	TRIPPED	MADE IT ON	01:45:00	01:55:00	