



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/10/2026

Area: OHP

Equipment	Job
BRC ON CO 30	LIGHTING DONE
CO-25 AND CO-26 WBR	SLEW LIMIT OILING DONE
IO-1 TO IO-11	INSPECTION GLASS WINDOW CHECKED .. SHEET CUTTING DONE
CO-33M	SPACE HEATER PLUG REPLACED
CO -30 BRC CO-24 TBS	PPM DONE
CO-16A	BRS CANOPY PROVIDED AND BRS KEPT IN CKT
CO 2A RSCO10A	PPM DONE
VF SPARE MOTOR	OVERHAULING GOING ON
CO 11, 12,13,8,9 ,10,14,15	CJD INSPECTION AND TESTING DONE
CO-8A , 33A, 35A, 37A	MOTOR AND PANEL PPM DONE