



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 25	Slew Right Limit Switch Stuck	Made it free	15:00:00	15:15:00	
2	OHP	BRC on CO 8a	LT M2 , M4 Trip	Reset	19:05:00	19:15:00	
3	OHP	CR1	OLR acted	Reset	16:25:00	16:35:00	
4	CHP	S2 on CC 35 B/C	ZSS cage damaged	Replaced	14:35:00	15:00:00	
5	CHP	SCR 2 on CC 33 B/W	Drive tripped	Reset	16:25:00	16:35:00	
6	CHP	CC 111 BRS	Fuse Blown	Replaced	18:00:00	18:15:00	
7	CHP	CC 113a	OLR acted	Reset	17:40:00	17:45:00	
8	CHP	CC 51 a	OLR acted	Reset	20:30:00	20:50:00	
9	CHP	CC 24	ZSS module problem	Replaced	15:20:00	15:40:00	
10	IOSA	BRC on OC 15a B/W	ZSS acting	Sensitivity adjusted	17:35:00	17:45:00	