



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/08/2026

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO -8A	LT DRIVE TRIPPED	RESET DONE	08:40:00	08:50:00	
2	OHP	WBR ON CO -6A	NO POWER ACB TRIPPED	MADE ON	08:45:00	09:00:00	
3	OHP	CO-29	TRIPPED ON OLR	RESET DONE	10:45:00 12:40:00	10:55:00 12:45:00	
4	CHP	CC-58	STOPPED ON ZSS	TERMINALS TIGHTENING IN ZSS MODULE	10:10:00	10:30:00	
5	CHP	CC-131	TRIPPED ON OLR	RESET DONE	12:45:00	12:55:00	
6	WT	CP-1	NOT MOVING .. FWD LIMIT ACTED	RESET	08:30:00	08:40:00	
7	WT	CP-1	NOT MOVING	D-4 TRIPPED ... RESET DONE	11:30:00	11:35:00	
8	IOSA	L and T WBR	LT NOT WORKING	PCRD OT ACTED ... RELEASED	11:15:00	11:35:00	