



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/08/2026

Incharge(s): K SANKARA RAO

Shift: B

| Sl No | Area | Equipment       | Problem                                                                            | Action                                  | From     | To       | Remarks |
|-------|------|-----------------|------------------------------------------------------------------------------------|-----------------------------------------|----------|----------|---------|
| 1     | OHP  | CO-26           | OLR ACTED                                                                          | RESET DONE                              | 17:40:00 | 17:45:00 |         |
| 2     | OHP  | VS-4A           | OLR ACTED                                                                          | RESET DONE                              | 15:05:00 | 15:15:00 |         |
| 3     | OHP  | CO-58           | REPORTED NOT HEALTHY FOUND<br>CONTROL MCB TRIP DUE TO EARTH FAULT<br>IN PULL CHORD | FIELD WIRES REMOVED AND PC BY<br>PASSED | 19:45:00 | 19:55:00 |         |
| 4     | CHP  | CC-111<br>SCR-3 | B/C NOT RUNNING MPD TRIP                                                           | RESET DONE                              | 14:45:00 | 15:00:00 |         |