



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	20:30:00	20:40:00	
2	OHP	CO 29	OLR ACTED	RESET	20:50:00	21:00:00	
3	OHP	BRC ON CO 33M	CT EMERGENCY PB ACTED	RELEASED	19:00:00	19:20:00	
4	CHP	CC 28	OLR ACTED	RESET	16:30:00	16:40:00	
5	CHP	CC 19	OLR ACTED	RESET	16:45:00	16:55:00	
6	CHP	CC 125	OLR ACTED	RESET	20:00:00	20:05:00	
7	CHP	SCR 3 ON CC 37 B/C	SLEW 30 DEGREE LIMIT ACTED	RELEASED	14:25:00	14:35:00	
8	CHP	SCR 4 ON CC 32	LT PCRD O/T ACTED	RELEASED	17:45:00	18:00:00	
9	WT	CC 3	ZSS PROBE DAMAGED	REPLACED	14:15:00	14:35:00	
10	WT	OP3	TOP COLLECTOR FALLEN AND C CLAMP DAMAGED	REPLACED	17:40:00	18:40:00	
11	WT	OT 3	D2 TRIP	RESET	21:00:00	21:05:00	