



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2026

Shift: A

Incharge(s): Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-6A BD	TRIPPED ON OLR	RESET DONE	07:40:00 08:05:00	07:50:00 08:10:00	
2	OHP	CO-26	TRIPPED ON OLR	RESET DONE	09:50:00	10:00:00	
3	OHP	CO-8A BRC	CT DRIVE TRIPPED	RESET DONE	10:55:00	11:05:00	
4	OHP	VF-10A	TRIPPING ...	CABLE JOINT DONE BOTH MOTORS .. MOTORS MEGGERED AND FOUND OK ... TESTED	06:00:00	07:00:00	
5	CHP	CC-131	TRIPPED ON OLR	RESET DONE	09:30:00 11:50:00	09:35:00 11:55:00	
6	CHP	CC-39 R-1	BC NOT RUNNING	PULLY SLIPPING MATERIAL JAMMING ... NO ELECTRICAL PROBLEM INFORMED OPR	08:42:00	09:00:00	
7	CHP	CC-37 SCR-3	BC NOT RUNNING	SIGNAL MISSING ...POWER RECYCLED	09:15:00	09:30:00	
8	CHP	CC-38	TRIPPED ON OLR 3 TIMES	RESET DONE	09:40:00	10:05:00	
9	CHP	CC-111 SCR-4	SIGNAL MISSING	LT DONE AND OBSERVED SIGNAL OK	10:44:00	11:10:00	
10	CHP	CC-58	ZSS MODULE PROBLEM FROM C SHIFT	MODULE CHANGED AND TESTED	06:00:00	06:30:00	
11	WT	CT-1	INHAUL OLR ACTED	RESET DONE	08:25:00	08:35:00	