



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2026

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 14 b	olr acted	reset	23:30:00	23:40:00	2 times
2	OHP	CO 25	olr acted	reset	23:45:00	23:55:00	3 times
3	OHP	BRC on CO 28	B/C not running,EMG acted in operator cabin side	released	00:34:00	00:50:00	
4	OHP	WOBR on CO 6A	b/c not running,yard conveyor ZSS interlock,position disturbed	re-positioned	00:35:00	01:00:00	
5	OHP	wobr on co 6A	b/w not running,stone stucked	informed to operation and mechanical	03:15:00	03:30:00	
6	CHP	CC 51 A	motor tripped on OL	reset	00:00:00	00:05:00	2 times
7	CHP	CC 131	motor tripped on OL	reset	02:05:00	02:10:00	2 times
8	CHP	CC 32 SCR5	LT not working,M2 mpcb tripped	made it on	00:25:00	00:35:00	
9	CHP	CC 37 SCR3	b/c not working,MPD tripped	reset	03:40:00	03:50:00	
10	CHP	CC 29	CS and TT CS healthy not coming,cable problem,	bypassed in program	23:10:00	23:20:00	to be checked in G shift
11	WT	CP 1	no movement,D4 OLR acted	reset	01:00:00	01:05:00	