वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 24/10/2026

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CO 34 | OLR acted | Reset | 17:55:00 | 18:05:00 | |
| 2 | OHP | TBS on co 7a Luff | Drive Trip | Reset | 17:10:00 | 17:20:00 | |
| 3 | CHP | CC 51 | Feeding conv OLR acted | Reset | 15:55:00 | 16:00:00 | 2 Times |
| 4 | CHP | CC 131 | OLR acted | Reset | 17:50:00 | 17:55:00 | |
| 5 | CHP | CC 25 | OLR acted | Reset | 14:10:00 | 15:55:00 | 2 times |
| 6 | CHP | CC 219 ZSS | Module Problem | Replaced | 14:45:00 | 15:00:00 | |
| 7 | CHP | CC 107 | OLR acted | Reset | 20:35:00 | 20:40:00 | |
| 8 | CHP | CC 125 | OLR acted | Reset | 20:55:00 | 21:00:00 | |
| 9 | CHP | SCR 9 on CC 104 Slew | MCCB tripped | Reset | 20:50:00 | 21:05:00 | |