



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/09/2026

Shift: B

Incharge(s): Nagendra Midde, G Eswara Rao

| Sl No | Area | Equipment        | Problem                        | Action                | From     | To       | Remarks                     |
|-------|------|------------------|--------------------------------|-----------------------|----------|----------|-----------------------------|
| 1     | OHP  | WBR on CO 6A B/C | Power MCCB trip                | Made it on            | 18:10:00 | 18:20:00 |                             |
| 2     | OHP  | BRC on CO 28 B/W | Power MCCB trip                | Reset                 | 18:30:00 | 18:40:00 |                             |
| 3     | OHP  | WBR on CO 29     | B/C C/S not resetting          | Bypassed              | 18:45:00 | 19:00:00 | Informed to Instrumentation |
| 4     | OHP  | CO 50            | OLR acted                      | Reset                 | 15:00:00 | 15:10:00 |                             |
| 5     | OHP  | RSCO 6A CD       | Mpcb trip due to Track jamming | Reset                 | 16:00:00 | 16:10:00 |                             |
| 6     | OHP  | RBF 3a CD        | OLR acted due to track Jamming | Reset                 | 19:40:00 | 19:50:00 |                             |
| 7     | CHP  | CC 58            | OLR acted                      | Reset                 | 19:00:00 | 19:15:00 |                             |
| 8     | CHP  | CC 54            | OLR acted                      | Reset                 | 20:10:00 | 20:20:00 |                             |
| 9     | CHP  | CC 112           | DE C/S acted due to rain       | Probe cleaned then ok | 16:00:00 | 16:15:00 |                             |