



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 29	grad running indication not coming, control is in off due to down limit acted	informed operation and made it on	12:00:00	12:15:00	
2	OHP	wobr on co 29	b/w not moving, mccb tripped	mccb made on	12:15:00	12:20:00	
3	OHP	CO 84	OLr acted	reset	13:44:00	13:50:00	
4	CHP	CC31	mpr tripped	reset	07:00:00	07:10:00	
5	CHP	CC 131	tripped due to olr	reset	07:10:00	07:15:00	3 times
6	CHP	CC 51	mpd acted	reset	12:00:00	12:05:00	2 times
7	CHP	CC 52	mpd tripped	reset	12:10:00	12:15:00	