



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tt 2 on co 16	flap gate tripped on MPCB	MADE ON	09:10:00	09:15:00	
2	OHP	co 29	tripped on olr	reset done	08:55:00	09:00:00	
3	OHP	CO 25	TRIPPED ON OLR	RESET DONE	13:05:00	13:10:00	
4	OHP	TBS ON CO 22	NO DRIVES RUNNING/MAIN CONTROL TRIPPED ON EARTH FAULT	AT CONTROL BUS BAR ELEMINATE D THE EARTH FAULT WITH BELT PIECE	09:40:00	09:50:00	TO PERMIN ENT
5	WT	OP 5	F/R NOT TAKING PLACE	C CLAMP GOT DAMAGED/REPLACED	12:45:00	13:00:00	