



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/04/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	00:50:00	04:20:00	3 TIMES
2	OHP	TBS ON CO 5A LT	PCRD O/T ACTED	RELEASED	02:15:00	02:25:00	
3	CHP	CC 31	OLR ACTED	RESET	05:30:00	05:35:00	
4	CHP	CC 28	OLR ACTED	RESET	05:45:00	05:50:00	
5	CHP	CC 201	OLR ACTED	RESET	03:35:00 23:45:00	03:45:00 23:55:00	
6	CHP	CC 107	OLR ACTED	RESET	01:05:00	05:25:00	3 TIMES
7	WT	CT 1 NOT MOVING	EMERGENCY SWITCH CONTACT NOT CONTACTING PROPERLY	PROPERLY PLACED	04:00:00	04:45:00	
8	WT	C P 2	BREAKER TRIP	MADE IT ON	03:05:00	03:20:00	