



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/04/2026

Area: CHP

Equipment	Job
CC-7	Motor and panel side ppm done
CC-13 MD	Testing is under progress
CC-117 TT	Control cable damaged part identified.
CC-57,58,116,117	Power supply isolated for damaged cables. Cables identification done.
Misc	CM-18 cleaning work done
CCR	Siemens scalance replaced and NodeRed communication established
SCR-8	Slew and Luff instrumentation field devices cleaning done
CC-43,44 TUNNEL	Lighting rectification done
SCR-8	Feed table ZSS cage modified to ladder type ZSS cage
CC-104	HT coupler heating, cleaning and IR value checking done. Found OK
STK-2	shifted to CC-104 bed