RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 10/11/2026

Area: CHP

Equipment	Job
CC 28 spare	New motor coupling fixed and shifted to JH C 6
SCR 6	Welding supply MCB replaced
CC 215/216 D/E	Sump pump motor replaced and trail taken
CC 26,26A,TT, 40,SCR 7	PPM done
CC 35T/E,R 1 cabin top	lighting improved
CC 215	Belt scale unit maintenance done
SCR 3,SCR 8	Instrumentation sensors maintenance done
CC 116	PC ckt made trough up to CJB
VS 3,VF 3,CC 132	PPM done