# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

Date: 09/11/2026

Area: OHP

| Equipment | Job |
|---|---|
| CO-5A BRS | Sensors return mode changed and restored in circuit , relay removed and restored to om-16 io rack. |
| cr-2 | De side greasing is done. |
| CR-3 removed motor | shifted to CME |