वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/11/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	17:20:00	17:30:00	
2	OHP	BRC on CO 28 LT	Field bus fault in drive	Reset	15:00:00	15:25:00	
3	OHP	CO 26	OLR acted	Reset	17:50:00	20:00:00	2 times
4	OHP	CO 50	OLR acted	Reset	20:25:00	20:35:00	
5	CHP	SCR 7 on CC 40 B/C	Modem OK PLc not communicating	PlC power Recycled	14:30:00	15:00:00	
6	CHP	CC 36	B/s Switch Problem	Bypassed	17:40:00	17:50:00	
7	CHP	CC 131	OLR acted	Reset	19:45:00	19:50:00	
8	WT	OP9	OT5 Control MCb trip	Made it on	16:45:00	16:50:00	