वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 22/10/2026

Area: WT

Equipment	Job
MIS	2 nos Spare 'DELTA' P L C panels shifted to new building
CP 1	D4 VFD removed and shifted to new building for repair
OP 4	D4 motor changing and testing done
OP 4	Panel and Motor side ppm done
OP 8	Panel and Motor side ppm done