# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

Date: 14/10/2026

Area: CHP

| Equipment | Job |
|---|---|
| CC 8 | Faulty MCCB replaced with Schneider 630A MCCB and trail run taken. 2nos jumper lugs replaced |
| SCR 3 | Instrumentation sensors maintenance was done |
| CC 49/50 gallary | 6 nos 30W LED lamps replaced and improved lighting |
| CC 47/48 | Tunnel area 4 nos 30W LED lamps replaced |
| SCR 8 | LT panel control supply MCB replaced |
| CC 107,108,125 | PPM was done |
| CM 9,CM 19,CM 27 | Bus bar maintenance was done |