वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 14/10/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on Co 20 LT	M1 trip	Reset	14:40:00	15:40:00	2 times
2	OHP	TBS on co 7a	Left Luff OLR acted	Reset	14:40:00	15:00:00	
3	CHP	SCR 1 on CC 31	Position bit not coming	Slew done properly	16:05:00	16:20:00	
4	CHP	S3 on CC 112 lt	PCRD O/T	Released	18:30:00	18:45:00	
5	CHP	SCR 8 on CC 106 LT	Earth fault in XDI -9	Removed	21:00:00	22:30:00	
6	CHP	CC 51	Feeding conv OLR acted	Reset	17:20:00	17:25:00	
7	CHP	CC 52	Feeding conv OLR acted	Reset	17:35:00	19:35:00	2 times
8	CHP	CC 28	OLR acted	Reset	21:10:00	21:20:00	
9	CHP	CC 28 T/T C/S	Due to rain water	Covered with Belt Piece	20:40:00	20:50:00	