



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/07/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	Reset	15:35:00	15:45:00	
2	OHP	CO 34	C/S Fuse loose	Tightened	16:10:00	16:20:00	
3	OHP	WBR on CO 29 B/W	OLR acted	Reset	20:45:00	20:55:00	
4	CHP	CC 52	Feeding conv OLR acted	Reset	14:30:00	14:35:00	
5	CHP	CC 51	Feeding conv OLR acted	Reset	14:50:00	14:55:00	