



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE	06:05:00	06:10:00	
2	OHP	WOBR ON CO 29	LUFFING NOT TAKING PLACE OLR ACTED	RESET DONE	11:45:00	11:50:00	
3	CHP	CC 27	REPORTED /MCCB TRIPPED DUE TO 2 LUGS GOT BURNT AT PLNEL OUT GOING.	LUGS AND FINGER CONTACTS REPLACED AND GIVEN CLEARENCE	07:20:00	11:00:00	
4	CHP	CC 28	TRIPPED ON OLR	RESET DONE	09:30:00	09:40:00	
5	CHP	CC 201	TRIPPED ON OLR	RESET DONE	06:45:00	06:55:00	
6	CHP	SCR 2 ON CC33	PCRD FAST ACTED	RESET DONE	09:10:00	09:15:00	
7	CHP	SCRC 2 ONCC 33	BC NOT RUNNING/OLR ACTED	RESET DONE	12:35:00	12:45:00	
8	CHP	SCR 3 ON CC37	BW NOT RUNNING/	PUMP ON COMMAND GIVEN THEN OK	10:15:00	10:25:00	WRONG C OMPLAINT