



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/07/2026

Area: OHP

Equipment	Job
om-29 in 1-141lc3	control bus ppm is done. 1-141lc3 both floors housekeeping is done.
om-29 in 1-141lc3	control bus ppm is done. 1-141lc3 both floors housekeeping is done.
co-61,64,65	safety devices ppm is done.
co-61,64,65	safety devices ppm is done.
co-31a gallery near co-20 point	lighting improved
co-31a gallery near co-20 point	lighting improved
co-8 reoved motor	coupling removed and shifted to lbds-4 and 5
co-8 reoved motor	coupling removed and shifted to lbds-4 and 5
LOSP-2 lighting	circuit problem rectified and restored some fixtures.
LOSP-2 lighting	circuit problem rectified and restored some fixtures.
co-17a hoist	ct motor failed, removed and shifted to lc-7 , spare to be found. Main hoist brake to be checked further.
co-17a hoist	ct motor failed, removed and shifted to lc-7 , spare to be found. Main hoist brake to be checked further.
Al Earthing jumpers	8 no.'s preparation is done at hvmmc-1. House keeping of hvmmc-1 , om-22 is done. HVMCC-1 surroundings lighting is improved.
Al Earthing jumpers	8 no.'s preparation is done at hvmmc-1. House keeping of hvmmc-1 , om-22 is done. HVMCC-1 surroundings lighting is improved.
co-82	motor and panel side ppm is done.
co-82	motor and panel side ppm is done.