



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/09/2026

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 30	CT NOT TAKING PLACE/IN LOCAL MODE	KEPT IN REMOTE	15:50:00	16:05:00	
2	OHP	CO 34	TRIPPED ON OLR	RESET DONE	20:00:00	20:05:00	
3	OHP	CO 34	BRS ACTING/MALFUNCTIONING	BYPASSED AT MODULE	17:15:00	18:00:00	TO KEPT IN CKT
4	OHP	CO 36	TRIPPED ON PHASE LOSE/MCCB Y PHASE MISSING	MCCB MADE OFF/ON 3times THEN ok	16:50:00	17:30:00	
5	CHP	CC 52	MPD TRIPPED ON OLR	RESET DONE	15:55:00	16:05:00	
6	CHP	S2 ON CC35	MPD TRIPPED ON OLR	RESET DONE	18:05:00	18:15:00	
7	CHP	SCR 3 ON CC36	TRIPPED ON OLR	RESET DONE	19:05:00	19:15:00	
8	CHP	R1 ON CC 39	BC NOT RUNNING/SIGNAL MISSING ZSS ACTING.	CAGE and PROBE ,MODULE REPLACED	18:50:00	20:00:00	
9	IOSA	IOSA	COMMUNICATION PROBLEM	LC 9 I/O RACK POWER KEPT OFF	19:40:00	20:50:00	