



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/04/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	tripped on olr	reset done	07:40:00	07:50:00	
2	OHP	WOBR ON CO 6A	LT NOT TAKING PLACE/M 5 GOT EARTH FAULT	TERMINATION DISCONNECT ED AT PANEL TB	07:00:00	07:30:00	PH.SEQ R,Y,B