



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 22	LT not working,drive tripped in ol	reset	17:55:00	18:05:00	
2	OHP	co 25	olr acted	reset	20:45:00	20:55:00	
3	CHP	cc 52	mpd acted	reset	19:00:00	19:05:00	
4	IOSA	OC7B	PC acted,relay problem	bypassed PC	21:00:00	21:20:00	