वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 16/10/2026

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | CO 44 | Drive MCCB failed, Fuses Blown | Given in DOL | 23:00:00 | 02:00:00 | Drive to be checked |
| 2 | OHP | TBS on CO 24 | Lt Drive trip | Reset | 00:50:00 | 01:00:00 | |
| 3 | OHP | BRC on CO 32 | PCRD o/t acted | Released | 04:05:00 | 04:20:00 | |
| 4 | OHP | CO 29 | OLR acted | Reset | 23:30:00 | 06:00:00 | 2 times |
| 5 | OHP | VF 10 a | OLR acted | Reset | 03:30:00 | 03:40:00 | |
| 6 | CHP | CC 29 F/G | OLR acted | Reset | 22:35:00 | 22:45:00 | |
| 7 | CHP | CC 15 | OLR acted | Reset | 01:30:00 | 01:40:00 | |
| 8 | WT | CO 4 CD | Not moving | Power Recycled then ok | 22:40:00 | 22:45:00 | |