



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/08/2026

Shift: A

Incharge(s): G Eswara Rao,K SANKARA RAO

| Sl No | Area | Equipment     | Problem                                                                 | Action                                   | From     | To       | Remarks |
|-------|------|---------------|-------------------------------------------------------------------------|------------------------------------------|----------|----------|---------|
| 1     | OHP  | CO-26         | OLR ACTED                                                               | RESET DONE                               | 08:10:00 | 08:20:00 |         |
| 2     | OHP  | CO-25         | OLR ACTED                                                               | RESET DONE                               | 09:10:00 | 09:20:00 |         |
| 3     | OHP  | BF-3A         | STOPPING ON ZSS FOUND ZSS GAPE PROBLEM                                  | PROBE GAPE ADJUSTED THAN OK              | 09:35:00 | 09:50:00 |         |
| 4     | OHP  | BRC ON CO-33M | REPORTED LT NOT TAKING PLACE FOUND M-1 OLR ACTED (DUE TO TRACK JAMMING) | RESET DONE AND INFORMED TO OPERATION     | 11:30:00 | 11:50:00 |         |
| 5     | CHP  | CC-40 SCR-7   | B/C OLR ACTED (DUE BELT SLIP)INFORMED TO MECHANICAL                     | RESET DONE                               | 10:15:00 | 11:00:00 |         |
| 6     | CHP  | CC-220        | REPORTED STOPPING ON ZSS FOUND ZSS MODULE PROBLEM                       | ZSS MODULE REPLACED WITH NEW ONE THAN OK | 11:45:00 | 12:00:00 |         |
| 7     | CHP  | CC-54         | MPD TRIP ( 3TIMES)                                                      | REST DONE                                | 10:05:00 | 10:20:00 |         |
| 8     | CHP  | CC-131        | OLR ACTED                                                               | RESET DONE                               | 12:55:00 | 13:00:00 |         |
| 9     | CHP  | CC-18         | BRS ACTED                                                               | RESET DONE                               | 10:45:00 | 10:55:00 |         |
| 10    | CHP  | CC-201        | OLR ACTED                                                               | RESET DONE                               | 10:42:00 | 10:50:00 |         |