



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/08/2026

Shift: C

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment       | Problem                                                            | Action                            | From                 | To                   | Remarks |
|-------|------|-----------------|--------------------------------------------------------------------|-----------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | CO-29           | OLR ACTED (2TIMES)                                                 | RESET DONE                        | 00:05:00<br>05:30:00 | 00:15:00<br>05:40:00 |         |
| 2     | OHP  | TBS ON<br>CO-20 | REPORTED L/BOOM STOPPING ON ZSS<br>CHECKED AND FOUND NO PROBLEM    | WRONG COMPLAINT                   | 00:55:00             | 01:10:00             |         |
| 3     | CHP  | TT ON<br>CC-28  | F/G MPCB TRIP                                                      | MADE ON                           | 00:35:00             | 00:40:00             |         |
| 4     | CHP  | CC-52           | MPD TRIP (FEEDING CONVEYOR STOP )                                  | RESET DONE                        | 02:20:00             | 02:25:00             |         |
| 5     | CHP  | CC-112<br>SCR-8 | REPORTED B/C NOT RUNNING FOUND ZSS<br>CAGE STUCK UP WITH COAL PICK | REMOVED COAL PICK THAN OK         | 02:30:00             | 02:45:00             |         |
| 6     | CHP  | CC-31<br>SCR-1  | LT DRIVE TRIP (OVN) FAULT                                          | RESET DONE                        | 05:35:00             | 05:50:00             |         |
| 7     | IOSA | L AND T<br>WOBR | REPORTED SLEW NOT WORKING                                          | LUFFING UP DONE THAN SLEW WORKING | 02:25:00             | 02:50:00             |         |