



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/09/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	08:00:00	08:10:00	
2	OHP	brc on co 32	CT not working,mccb is in off	made on	12:45:00	12:50:00	
3	CHP	CC 39 R1	b/c not working,wrong complain	CPP side not running	07:30:00	07:45:00	
4	CHP	CC 40 SCR7	all drive not working,acb is in off,emergency acted by operator	emergency released and ACB made on	10:55:00	11:00:00	
5	CHP	CC 38 SCR6	slew R not working,30 degree limit acted	released than ok	13:15:00	13:20:00	
6	CHP	CC 31 SCR1	brs acted,alignment problem	alignment adjust	13:25:00	13:35:00	