



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/09/2026

Incharge(s): Nagendra Midde, Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	01:05:00	01:10:00	
2	OHP	CO 26	OLR acted	Reset	03:45:00	05:50:00	2 times
3	OHP	WBR on co 6a LT	M6 trip	Reset	22:40:00	22:50:00	
4	OHP	WBR on CO 25	Slew Drive trip	Reset	01:25:00	01:35:00	
5	OHP	CO 10a	OLR acted	Rset	23:00:00	23:15:00	
6	OHP	CO 12a	BRS not resting	Properly Cleaned then ok	00:40:00	00:50:00	
7	OHP	VF 10a	OLR acted	Reset	00:50:00	01:00:00	
8	CHP	CC 131	OLR acted	Reset	01:10:00	01:15:00	