वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 06/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 48	OLR acted	Reset	03:35:00	03:55:00	
2	OHP	CO 56	OLR acted	Reset	04:10:00	04:25:00	
3	OHP	TBS on CO 7a LT	Selector Switch in local	Changed to Remote	22:45:00	23:00:00	
4	OHP	CO 26	OLR acted	Reset	00:50:00	04:05:00	3 times
5	OHP	BRc on CO 31 B/C	OLR acted	Reset	05:00:00	05:15:00	
6	OHP	CO 35	P/C fuse Blown	Bypassed	22:50:00	23:05:00	
7	CHP	CC 28 T/T	Position Sensor Got Misplaced	Adjusted	23:15:00	23:30:00	
8	CHP	CC 131 T/T	Position On Rg2 Not coming	Signal Made High	05:00:00	05:15:00	