



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/08/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

| Sl No | Area | Equipment       | Problem            | Action     | From                 | To                   | Remarks |
|-------|------|-----------------|--------------------|------------|----------------------|----------------------|---------|
| 1     | OHP  | CO-25           | OLR ACTED( 2TIMES) | RESET DONE | 15:40:00<br>17:15:00 | 15:55:00<br>17:25:00 |         |
| 2     | OHP  | CO-26           | OLR ACTED          | RESET DONE | 18:30:00             | 18:40:00             |         |
| 3     | OHP  | BRC ON<br>CO-28 | B/C OLR ACTED      | RESET DONE | 21:10:00             | 21:15:00             |         |
| 4     | CHP  | CC 40           | OLR acted          | Reset      | 16:30:00             | 16:35:00             |         |
| 5     | CHP  | CC 52 TIS       | Motor Olr acted    | Reset      | 19:30:00             | 19:40:00             |         |
| 6     | CHP  | CC 54           | OLR acted          | Reset      | 21:10:00<br>21:30:00 | 21:20:00<br>21:40:00 |         |
| 7     | CHP  | CC 115<br>BRS   | Alignment problem  | Readjusted | 21:00:00             | 21:30:00             |         |