



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/09/2026

Area: CHP

Equipment	Job
CC 201,202	PPM done and all JBs maintenance done
PCRD spare	Motor overhauling done and trail run was taken
SCR 9	Instrumentation sensors maintenance was done
SCR 3	PPM was done
CC 47/48	Spare motor coupling fixed and shifted to location
CC 222/223	Lighting ckt problem rectified and improved lighting
CC 43/44 tunnel	5 nos 30W LED lamps replaced
SCR 3,CC 32	Running inspection defect rectified
CC 55 Belt Scale	Calibration done
CC 55,56,57,58,TT	PPM was done