



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/05/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 20 BRS	CABLE GOT CUT	REJOINED	08:40:00	09:00:00	
2	CHP	CC 58 OLR ACTING FR EQUENTLY	ALL CONNECTIONS TIGHTEND	THEN OK	06:00:00	07:00:00	
3	CHP	CC 107	OLR ACTED	RESET	13:00:00	13:10:00	