



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/07/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment     | Problem                                                                | Action                    | From     | To       | Remarks |
|-------|------|---------------|------------------------------------------------------------------------|---------------------------|----------|----------|---------|
| 1     | OHP  | co 25         | olr acted                                                              | reset                     | 06:35:00 | 06:45:00 |         |
| 2     | OHP  | WOBR on CO 25 | LT not working,OT acted                                                | OT released               | 06:35:00 | 06:45:00 |         |
| 3     | OHP  | CR 2A         | tripped in unbalanced load,checked and found R phase lug got cut in TB | megger done ,lugging done | 08:00:00 | 11:55:00 |         |
| 4     | CHP  | CC 131        | tripped                                                                | reset                     | 08:40:00 | 08:45:00 | 3 times |