



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/07/2026

Shift: C

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 29	BW NOT RUNNING/OLR ACTED DUE TO JAMMING 2 TIMES	RESET DONE	00:30:00 23:30:00	00:40:00 23:45:00	
2	OHP	CO 26	TRIPPED ON OLR /2TIMES.	RESET DONE	00:30:00 05:00:00	00:45:00 05:10:00	
3	OHP	CO 29	TRIPPED ON OLR	RESET DONE	02:30:00	02:40:00	
4	OHP	CO 3A.9A,12A	NO POWER/ 6.6KV TRIPPED ON U/VOLTAGE AT 1-28HVMCC4 OF INCOMER 2 AND 1-28 LBDS8 OF HVMCC4	INCOMER -2 and HVMCC4 BREAKER S MADE ON THEN TESTED OK	01:55:00	02:25:00	
5	OHP	VS 2A	TRIPPED ON OLR	RESET DONE	02:00:00	02:15:00	
6	CHP	CC 58	TRIPPED ON OLR	RESET DONE	22:30:00	22:45:00	
7	CHP	CC 52	TRIPPED ON OLR	RESET DONE	23:10:00	23:15:00	
8	CHP	SCR 7 ON CC 40	B/W NOT STARTING	OPERATOR FAULT	04:30:00	04:40:00	
9	CHP	SCR 9ON CC 213	BW NOT RUNNING/MCCB TRIPPED	MCCB MADE ON	01:50:00	02:00:00	
10	CHP	SCR 6 ON CC38	SLEW TRIPPED ON OLR	RESET DONE	03:10:00	03:20:00	
11	WT	OT 3	DRIVE 1 TRIPPED ON ENCODER FAULT 43	RESET DONE	23:50:00	23:55:00	