RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

वी.एस.पी
VSP

Date: 09/11/2026

Area: CHP

Equipment	Job
CC 131	Spare motor shifted near to running motor
SCR 7	Instrumentation sensors maintenance done
CC 35,45,47,213,S 2,SCR 8	PPM done
SCR 9 slew tripping	Cable chamber inspected for any cable damage,not found
R1	Position sensor replaced and kept in ckt
LC 16(CM 14)	Bus bar maintenance done