वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/10/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR on CO 29 LT	No Electrical Problem	Informed to mech	01:50:00	02:00:00	
2	CHP	SCR 9 on CC 104	Slew Control MCB trip	Made it on	04:05:00	04:15:00	