



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/06/2026

Area: WT

Equipment	Job
CO-2	MOTOR AND PANEL SIDE PPM DONE
OP-4	LIGHTING DONE AND D1 MOTOR DAMAGED LUG REPLACED
OP-4	D-6 ALIGNMENT DONE
OP-5	PANEL SIDE PPM DONE
OP-6	TROLLEY LINE CROSS ARM WELDING JOB GOING ON