# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL GENERAL SHIFT REPORT

Date: 13/10/2026

Area: WT

| Equipment | Job |
|---|---|
| OP 6 | Trolley line cross Arms welding done 10 units |
| OP 8 | Trolley line damaged insulators replaced 27 nos |