RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 12/10/2026

Area: OHP

Equipment	Job
co-20 brs	module and sensors changed and restored in circuit.
CO 14 B	Chute Vibrator Kept in circuit
VS2	Old motor Shifted to LC7
CO 50 To CO 51	New Chute vibrator Installed, Connections Given and given in Local
OM 15, OM 33	Control Bus PPM done
CO 61, CO 64	PPM done both Panel side and Feeder side